



कार्यालय-प्रधानाचार्य, राजस्वा.वि.वि.आयुर्विज्ञानमहाविद्यालय, जयपुर
Office of the Principal & Controller, RUHS College of Medical Sciences, Jaipur
(Constituent College of Rajasthan University of Health Sciences, Jaipur)
Address :Sector-11, KumbhaMarg, Pratap Nagar, Tonk Road, Jaipur -302033(Rajasthan)

Contact :

Phone : +91-141-2795634
Fax : +91-141-2795550



Website : www.ruhscms.org
Email: principalruhscms@ruhsraj.org
ruhscmsstore@ruhsraj.org

No. RUHS CMS/Store/2021-22/ 8095

Dated: 15.07/2021

प्रस्ताव आमंत्रण सूचना

राज.स्वा.वि.वि. आयुर्विज्ञान महाविद्यालय चिकित्सालय मे स्थापित FIRE DETECTION SYSTEM के व्यापक वार्षिक रख-रखाव (CAMC) कार्य हेतु प्रस्ताव आमन्त्रण सूचना।

राज.स्वा.वि.वि. आयुर्विज्ञान महाविद्यालय चिकित्सालय मे स्थापित **FIRE DETECTION SYSTEM** के व्यापक वार्षिक रख-रखाव (CAMC) कार्य हेतु दर प्रस्ताव आमंत्रित किये जाते हैं। जिसमें इच्छुक फर्म ऑनलाईन प्रपत्र डाउनलोड कर कार्यालय में दिनांक 28/07/2021 को प्रातः 11.00 बजे तक व्यक्तिशः अथवा महाविद्यालय केन्द्रीय भण्डार शाखा कार्यालय की ई-मेल आईडी ruhscmsstore@ruhsraj.org पर प्रेषित कर प्रस्ताव के माध्यम से दर प्रस्ताव प्रस्तुत कर सकता है।

नियम एवं शर्तें :-

1. The Request for Proposal shall be effective and valid for the period of One year from the date of work order. It may be extended by written mutual consent of both parties as per rules.
2. Maintenance services shall be provided by the firm at RUHS Medical Hospital, Jaipur.
3. The scope of coverage of the Request for Proposal for the Fire detection System. AMC Should cover all the items related to Fire detection System including its accessories and its wiring parts and all other parts also.
4. Approved service provider shall rectify any defects, faults, physical damage and failures in the equipment and shall repair, replace any worn out, defective parts of the equipment, free of cost to Superintendent RUHS Medical Hospital. If any part of equipment is replaced by the approved firm, the old part must be submitted at Central Stores of RUHS Medical Hospital.
5. The Approved service provider shall configure the hardware items as the case may be in the equipment covered under Request for Proposal, at no extra cost to Medical Superintendent, RUHS Medical Hospital whenever the need arises.
6. Necessary technical assistance and advices shall be extended by the firm to resolve problems that may be encountered with regard to Fire detection System and peripherals covered under the Request for Proposal.
7. Approved service provider shall, work as per directions of Medical Superintendent RUHS Medical Hospital.
8. Approved service provider should provide management hierarchy for further communication.
9. Approved service provider should submit satisfactory performance along with submission of bill.
10. The Approved service provider shall repair/replace faulty parts on -site only. If it is not possible to repair/replace the part on site, then Approved service provider can carry the equipment to service center after approval of authority on its own cost. After repair/ replace of equipment/part firm have to install these their concerned place. Transportation charges should be borne by the Approved service provider. If the Approved service provider failed to compliance as per terms and conditions within 7 days otherwise penalty of Rs. 500/- per equipment/day may be imposed. Approved service provider carry any hardware to service center for repair, hardware should be repair and install at appropriate place within seven calendar days. If Approved service provider failed in the same then penalty of Rs. 1000/- per day/equipment may be imposed. by Medical Superintendent, RUHS Medical Hospital, Jaipur against Approved service provider. Approved service provider should replace faulty parts with original parts only.
11. The Approved service provider shall not sub-contract the Request for Proposal to any organization, person firm or its equipments/parts to franchisee without the prior approval of Principal, RUHS College of Medical Sciences, Jaipur. If, at any time, it comes to the notice of Principal, RUHS College of Medical Sciences,

कार्यालय-प्रधानाचार्य, राज०स्वा०वि०वि०आयुर्विज्ञानमहाविद्यालय, जयपुर
Office of the Principal & Controller, RUHS College of Medical Sciences, Jaipur
(Constituent College of Rajasthan University of Health Sciences, Jaipur)
Address :Sector-11, KumbhaMarg, Pratap Nagar, Tonk Road, Jaipur -302033(Rajasthan)

Contact :

Phone : +91-141-2795634
Fax : +91-141-2795550




Website : www.ruhscms.org
Email: principalruhscms@ruhsraj.org
ruhscmsstore@ruhsraj.org

No. RUHS CMS/Store/2021-22/

Dated:/.../2021

- Jaipur that such sub-letting has been done, Principal RUHS College of Medical Sciences, Jaipur at its discretion may terminate the contract without referring the matter further to the firm. Principal RUHS College of Medical Sciences, Jaipur will be at liberty to realize all the expenses it had to incur in this connection, either by adjusting from the payment due to the Approved service provider or through other means.
12. The payment to successful Approved service provider will be done by SMS Medical College upto the official end of Covid-19/re-affiliation of RUHS Medical Hospital with RUHS College of Medical Sciences, Jaipur. No. Financial liability / obligation will be borne by RUHS College of Medical Sciences, Jaipur till that.


प्रधानाचार्य,
राज०स्वा०वि०वि० आयुर्विज्ञान महाविद्यालय,
जयपुर।



कार्यालय-प्रधानाचार्य, राज०स्वा०वि०वि०आयुर्विज्ञानमहाविद्यालय, जयपुर
Office of the Principal & Controller, RUHS College of Medical Sciences, Jaipur
(Constituent College of Rajasthan University of Health Sciences, Jaipur)
Address :Sector-11, KumbhaMarg, Pratap Nagar, Tonk Road, Jaipur -302033(Rajasthan)

Contact :
Phone : +91-141-2795634
Fax : +91-141-2795550



Website : www.ruhscms.org
Email: principalruhscms@ruhsraj.org
ruhscmsstore@ruhsraj.org

No. RUHS CMS/Store/2021-22/

Dated:/..../2021

Annexure – 01

कार्य का विवरण:-

राज.स्वा.वि.वि. आयुर्विज्ञान चिकित्सालय में स्थापित FIRE DETECTION SYSTEM के व्यापक वार्षिक रख-रखाव (CAMC) कार्य	
क्र.सं.	कार्य
1.	प्रतिमाह फायर डिटेक्टर सिस्टम को चेक करना कि वह कार्य कर रहा या नहीं।
2.	फायर डिटेक्टर सिस्टम में लगे हुए सामान की देखरेख व खराब होने पर स्वयं के खर्चे पर बदलना।

डा. चन्द्रजीत सिंह चन्देल
चिकित्सा अधिकारी प्रभारी
कैम्पस भण्डार शाखा
राज. स्वा.वि.वि. आयुर्विज्ञान महाविद्यालय, जयपुर

कार्यालय-प्रधानाचार्य, राजस्वाविधिआयुर्विज्ञानमहाविद्यालय, जयपुर
Office of the Principal & Controller, RUHS College of Medical Sciences, Jaipur
(Constituent College of Rajasthan University of Health Sciences, Jaipur)
Address :Sector-11, KumbhaMarg, Pratap Nagar, Tonk Road, Jaipur -302033(Rajasthan)

Contact :
Phone : +91-141-2795634
Fax : +91-141-2795550



Website : www.ruhsCMS.org
Email: principalruhsCMS@ruhsraj.org
ruhsCMSstore@ruhsraj.org

No. RUHS CMS/Store/2021-22/

Dated:/...../2021


Annexure – 02

STATUS AND OFFER SHEET

In Reference to RUHS CMS RFP No.RUHS CMS/Store/2021-22/..... Dated / /2021

फर्म का नाम एवं पता	
PAN No (Enclosed copy)	
GST Registration (Enclosed copy)	
Experience Details	
Authorised Person's Contact Details	
नाम	
मोबाइल नम्बर	
ई.मेलआई.डी.	
अनुलग्नक 01 के अनुसार दर जी.एस.टी. के बिना	
अनुलग्नक 01 के अनुसार दर जी.एस.टी. के साथ	

I /WE have read the all terms and conditions of the RFP (EOI) and accept in all with my faith and belief and abide by them.


डॉ. चन्द्रजीत सिंह चन्देल
चिकित्सा अधिकारी प्रभारी
जयपुर
राज. स्वास्थ्य विज्ञान महाविद्यालय, जयपुर

(Signature)
Name of Signatory
Mobile No.
Seal of Company / Firm / Person